

POOR LEGIBILITY

ONE OR MORE PAGES IN THIS DOCUMENT ARE DIFFICULT TO READ
DUE TO THE QUALITY OF THE ORIGINAL

CITY OF MOUNTAIN VIEW

Public Works

March 28, 1967

Simpson, Stratta & Associates
 325 Fifth Street
 San Francisco, California

Attention: Mr. McLeod

Gentlemen:

RE: FAIRCHILD PLATING FACILITY, 644 NATIONAL AVENUE

Your plumbing and mechanical plans for the subject facility have been reviewed by Public Works Engineering.

We offer the following comments which should be incorporated into your plans:

1. City to install 8-inch fire line service upon application and payment of fees by the owner.
2. City to install manifold and two 2-inch water meters on the existing service upon application and payment of fees by the owner. The meters are to be located so as not to interfere with the existing 6-inch sewer lateral. (See attached plan). The backflow preventer is to be above ground and a detail is necessary showing additional valving and connections to the meters.
3. The storm drain system is to be connected to the existing 12" RCP stub located at the back of existing curb inlet on National Avenue as shown on the attached plan.
4. The sanitary line is to be connected to the existing 6" sanitary lateral shown on the attached plan. The sampling well and cleanout is to be located at property line rather than as shown on your plumbing plans.
5. All chemically treated water and degraded cooling water from the air conditioning system are to be drained to the industrial waste treatment facility. Water from these processes will not be allowed in the

 CITY OF MOUNTAIN VIEW 

storm drainage system.

6. The industrial waste neutralizing and pretreatment facility can only be reviewed upon submittal of pertinent information and a written request for approval. These have not been received and will be reviewed at that time.

The Public Works Building Division will review those plans for conformity with the Building Code. If you have any questions feel free to contact me.

Very truly yours,

ROGER HIGDON
Operations Engineer

sdp

enclosures

City Manager
Dir. Public Works
Asst. Dir. Public Works
Bldg.
McPheeters
Senior Engineer
Operations Engineer
E/v w/o